

Roof System Assessment Report of Wind Uplift Resistance (ISO 17025)

Document Number:	PUB-DRU292551
Publication Date:	2015-01-15
Revised:	2015-04-30
Revaluation Date:	2018-01-15

Supplier:



Mod-Bit system Fast-N-Stick 180 Base mechanically attached, Mechanically Attached Roof System (MARS)

Roofing System Summary:

Cap sheet membrane: Modified Bituminous Membrane or allowable products

Base sheet membrane: Modified Bituminous Membrane

- Cover board: Optional

Insulation: Polyisocyanurate or allowable products
 Vapour barrier: Membrane or allowable products

Thermal barrier: OptionalDecking: Steel Deck

- Dynamic Uplift Resistance (DUR)as per CSA A123.21:

Description	Test observation reading	With SF of 1.5
System A	-2.9 kPa(-60 psf)	-1.9 kPa(-40 psf)
System B	-7.2 kPa (-150 psf)	-4.8 kPa (-100 psf)

Notes: Allow products:

Only equivalent products included into the roofing system's report are admissible.

Optional components:

Components of the roofing system designated as optional may be included or excluded from the roofing system which will not change the published dynamic uplift resistance (DUR).

Safety factor:

As required by in the CSA A123.21 Standard, the published dynamic uplift resistance (DUR) are reduced by a safety factor of 1.5 (SF of 1.5)

Admissible wind uplift load calculation:

An online calculator is available at www.sigders.ca. The user will have to provide the following information:

- building location;
- building geometry;
- building exposure;
- building openings;
- building importance factor.

The calculator will display the allowable design load of the roof's field surface, edges and corners as well as the dimensions of the edge and corner zones.

Technical Advisories:

Assessment reports must be read in conjunction with technical advisories issued by exp Services Inc.

Values

For this document, the metric values are the standard and values in parentheses are for information only.

Notice:

Exp Services inc. reserve their right to withdraw, without prior notice, the test report performed as per CSA A123.21 Standard.

REV_2014-10-09 Page **1** of **3**



Roof System Assessment Report of Wind Uplift Resistance (ISO 17025)

Document Number:	PUB-DRU292551
Publication Date:	2015-01-15
Revised:	2015-04-30
Revaluation Date:	2018-01-15

Roofing System's Specific Data: <u>Cap Sheet Membrane:</u>

- Allowable products:	IKO	IKO				
	Torchflex TP-250 Cap	Prevent TP-250	Armourcool Granular TP-HD			
	Torchflex TPQ-250 Cap	Prevent Premium TP-250	Armourcool Granular Prevent TP-HD			
	Torchflex TP-HD	Prevent TP-HD	Armourcool Granular Prevent PremiumTP-HD			
	Torchflex TP-250 5 mm	Prevent Premium TP-HD	Armourcool Granular TP			
	Torchflex TP-180 Cap					
- Attachment mode:	Heat welded					


Base sheet membrane:

-	Allowable products:	IKO				
		Fast-N-Stick 180 Base Coversheild Base 180				
Me	chanically attached Pattern	Row spacing		Fa	Fasteners spacing	
	for System A result	890 mm (35 in)	o.c.	457	7 mm (18 in) o.c.	
-	Attachment type:	Fasteners #14 DP	Fasteners #14 DP			
		Round barbed plate, with Galvalume finish of 61 mm (2.4 in)MPB-2400				
-	Pullout fastener resistance:	225 psi or 492 lbf or 2189 Newton				
-	Attachment supplier:	Trufast				
Me	echanically attached Pattern	Row spacing)	Fa	steners spacing	
	for System B result	457 mm (18 in)	o.c.	305	5 mm (12 in) o.c.	
-	Attachment type:	Fasteners #14 DP				
		Round barbed plate, with Galvalume finish of 61 mm (2.4 in)			.4 in)	
-	Attachment supplier:	Trufast				

Cover board (optional): See optional products table

Insulation:

-	Allowable products:	IKO				
	, me nacie producto.	IKOTherm	IKOTherm Tapered		IKOTherm 25 Tapered psi	
		IKOTherm III	IKOTherm III 25 psi		IKOTherm 25 psi	
-	Allowable thickness:	Between 25 mm (1 in) et :	203 mm (8 in)	•	•	
Me	echanically attached Pattern	Row spacing Fast		steners spacing		
		One fastener every 4 f ²		A - Maalaa	nically pattern drawing	
1		One fastener ever	y 4 1 ²	AS Mecha	nically pattern drawing	
-	Attachment type:	II.	•		Galvalume with Hex head	
-	Attachment type:	II.	•		<u> </u>	
-	Attachment type: Pullout fastener resistance:	Pre-assembled # 12 Drill F	Point Fastener		<u> </u>	





Roof System Assessment Report of Wind Uplift Resistance (ISO 17025)

Document Number:	PUB-DRU292551
Publication Date:	2015-01-15
Revised:	2015-04-30
Revaluation Date:	2018-01-15

Vapour Barrier:

- Allowable products:	IKO		
	ArmourGard	MVP Vapour Retardant	
	Generic		
	Polyethylene	Kraft Vapour Retarder	
- Attachment mode:	Loose laid, adhered or mechanically attached		

Thermal Barrier (optional): See optional products table

Decking:

- Type:		Galvanized construction steel or coated with an aluminum/zinc alloy or PVC in accordance with ASTM A653, ASTM A792, ASTM A1008 or CSSBI 10M Standards.
- Supplie	er:	Generic
- Thickn	ess:	0.76 mm (0.03 in.) minimum, with a yield strength of 230 MPa (33 ksi) and a tensile strength of 310 MPa (45 ksi) commonly defined as being of a 22 gauge minimum thickness.
- Attachi	ment method:	The deck's fastening to the supporting structure must be strong enough to resist wind uplift loads (adjusted as per NBC requirements).
	ing uplift resistance S136.F04):	2.09 kN (470 pf)
- Equiva	llence:	Steel deck thickness of 18 to 22 gauges or wood deck or concrete deck with pullout resistance equal or higher than the Fastening uplift resistance specified above.

Optional Products Table:

Cover board:

-	Allowable product:	IKO				
		Protectoboard Protectobase 1		se 180	Covershield	
		Coversheild Base 180				
		Georgia Pacific			·	
		Dens deck Prime		k Prime		
		CGC / USG				
		Securock Gypsum Fiber Roof Board				
		Generic				
		Roofing Gypsum board		Wood-fibe	er	
-	Allowable thickness:	Between 3 mm (1/8 in) to	25 mm (1 in)	n)		
-	Attachment mode:	Loose laid or adhered or mechanically at		ttached		

Thermal barrier:

-	Allowable product:	Georgia Pacific				
		Dens Deck Prime				
		CGC / USG				
		Securock Gypsum Fiber Roof Board				
		Generic				
		Roofing Gypsum board				
-	Allowable thickness:	Between 5 mm (3/16 in) to 25 mm (1 in)				
-	Attachment mode:	Loose laid or adhered or mechanically attached				

2400 rue Canadien, Drummondville (Québec) J2C 7W3 Tel.: 819 850-6247 www.exp.com