

## Roof System Assessment Report of Wind Uplift Resistance (ISO 17025)

Document Number:	PUB-DRU168534
Publication Date:	2010-12-05
Revised:	2015-04-30
Revaluation Date:	2018-04-30

#### Supplier:



### Mod-Bit Soprafix 630 wood deck mechanically attached System, Mechanically Attached Roof System (MARS)

#### **Roofing System Summary:**

Cap sheet membrane: Modified Bituminous Membrane or allowable products

- Base sheet membrane: Modified Bituminous Membrane

- Cover board: Optional

Insulation: Polyisocyanurate or allowable products
 Vapor barrier: Self-adhered membrane or allowable products

- Thermal barrier: Optional

Decking: Standard wood(plywood) deck

- Dynamic Uplift Resistance (DUR)as per CSA A123.21:

Description	Test observation reading	With SF of 1.5
System A	-3.6 kPa (-75 psf)	-2.4 kPa (-50 psf)

#### Note: Allow products:

Only equivalent products included into the roofing system's report are admissible.

#### **Optional components:**

Components of the roofing system designated as optional may be included or excluded from the roofing system which will not change the published dynamic uplift resistance (DUR).

#### Safety factor:

As required by in the CSA A123.21 Standard, the published dynamic uplift resistance (DUR) are reduced by a safety factor of 1.5 (SF of 1.5)

#### Admissible wind uplift load calculation:

An online calculator is available at <a href="www.sigders.ca">www.sigders.ca</a>. The user will have to provide the following information:

- building location;
- building geometry;
- building exposure;
- building openings;
- building importance factor.

The calculator will display the allowable design load of the roof's field surface, edges and corners as well as the dimensions of the edge and corner zones.

#### **Technical Advisories:**

Assessment reports must be read in conjunction with technical advisories issued by exp Services Inc.

#### **Values**

For this document, the metric values are the standard and values in parentheses are for information only.

#### Notice

**Exp** Services inc. reserve their right to withdraw, without prior notice, the test report performed as per CSA A123.21 Standard.

REV\_2014-10-09 Page **1** of **3** 



# Roof System Assessment Report of Wind Uplift Resistance (ISO 17025)

Document Number:	PUB-DRU168534
Publication Date:	2010-12-05
Revised:	2015-04-30
Revaluation Date:	2018-04-30

#### **Roofing System's Specific Data:**

#### Cap Sheet Membrane:

Allowable products:	Soprema	0 - 1 - 010 00	0 , [] , [] 0 0
	Sopralene Flam 180 GR	Sopralene Flam 250 GR	Soprastar Flam HD GR
	Sopralene Flam 180 FR	Sopralene Flam 250 FR	Soprastar Flam HD FR
	GR	GR	GR
	Sopralene Mammouth GR	Soprafix Traffic Cap 660	Soprafix Traffic Cap FR 661
Attachment mode:	Heat welded		

#### Base sheet membrane:

-	Allowable products:	Soprema			
		Soprafix Base 630			
Me	chanically attached Pattern	Row spacing		Fa	steners spacing
	for System A result	890 mm (35 in.) o	o.c.	457	' mm (18 in.) o.c.
-	Attachment type:	Fasteners #14 with #3 dee steel and covered with an a 20 gauges rounds barbed	anticorrosion o	coating.	nposed of hardened carbon alvalume finish
-	Pullout fastener resistance: Attachment supplier:	<b>214</b> psi or <b>442</b> lbf or <b>1967 Soprema</b>	' Newton		

<u>Cover board (optional):</u> See optional products table

#### Insulation:

- Allowable products:	Soprema	Soprema		
	Sopra-Iso	Sopra-Iso +	SopraRock DD	
	SopraRock DD Plus	SopraRock MD	SopraRock MD Plus	
	Atlas Roofing Corp.			
	ACFoam II	ACFoam III	ACFoam IV	
	Johns Manville			
	ENRGY 3	ENRGY 3 CGF		
	<b>Hunter Panels</b>			
	H-Shield	H-Shield CG		
- Allowable thickness:		Between 25 mm (1 in.) to 203 mm (8 in.)		
- Attachment mode:	Loose laid or adhered	or mechanically attached	d	

#### Vapor barrier:

-	Allowable products:	Soprema	
		Sopravap'R	Sopralene Stick Adhesive
-	Attachment mode:	Adhered	
-	Attachment type::	Self-adhered membrane	

#### Or Vapor barrier (option 1):

-	Allowable products:	Soprema		
		Sopralene 180 SP 3.5	Elastophene SP 2.2 mm	
-	Mode d'attachement:	Adhéré ou fixé mécanique	ment	

#### Or Vapor barrier (option 2):

-	Allowable products:	Soprema		
		Soprastop	Xpress Vap'R Board	
-	Mode d'attachement:	En indépendance ou adhé	ré ou fixé mécaniquement	

2400 rue Canadien, Drummondville (Québec) J2C 7W3 Tel.: 819 850-6247 www.exp.com



### **Roof System Assessment Report** of Wind Uplift Resistance (ISO 17025)

Document Number:	PUB-DRU168534
Publication Date:	2010-12-05
Revised:	2015-04-30
Revaluation Date:	2018-04-30

Thermal barrier (optional): See optional products table
---

#### Decking:

- Supplier:	CANPLY
- Decking type:	Exterior Douglass fir plywood in accordance with CSA 0121, CSA 0151, CSA 0153 standards, like EASY T&G, DFP select grade.
- Thickness:	17 mm (5/8 in.) minimum, correspondent to CSA 0121, CSA 0151, CSA 0153 standards with a load limit of L/180; 6 kPa (125 psf).
- Equivalence:	Other deck with pull-out resistance equivalent to the one specified below.
- Attachment method:	The deck's fastening to the supporting structure must be strong enough to resist wind uplift loads (adjusted as per NBC requirements).

#### **Optional Products Table:**

#### Cover board:

- Allowable products:	Soprema			
	Sopraboard	Soprarock MD	Soprarock MD+	
	Georgia Pacific			
	DensDeck	DensDeck Prime		
	CGC / USG			
	Securock Gypsum Fibe	r Roof Board		
	Unifix			
	PermaBase Dek			
<ul> <li>Allowable thickness:</li> </ul>	Between 6 mm (¼ in.) to 19.5 mm (5/8 in.)			
- Attachment mode:	Loose laid or adhered or mechanically attached			

#### **Thermal barrier:**

- Allowable products:	Georgia Pacific			
	DensDeck	DensDeck Prime		
	CGC / USG			
	Securock Gypsum Fiber Roof Board			
	Unifix			
	PermaBase Dek			
<ul> <li>Allowable thickness:</li> </ul>	Between 6 mm (1/4 in.)	Between 6 mm (1/4 in.) to 19.5 mm (5/8 in.)		
- Attachment mode:	Loose laid or adhered or mechanically attached			

REV\_2014-10-09